## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

**LISTING No.** 7165-1591:144 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

**LISTEE:** Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243

Contact: Leon Newsome (941) 739-4276 FAX (941) 739-4334

**DESIGN:** Model ESA 2000 system. Coded or non-coded; local, auxiliary, remote station and central

station service. Refer to listee's data sheet for detailed product description and

operational considerations. Minimum system:

 2025-000
 Base Panel

 2025-700/701/702
 CPU Units

 2016-001
 Display Module

 2001-001
 Input Zone Module

 2002-001
 Output Module

2003-401 Output Module (Aux. Relay)
2012-201 Addressable Loop Controller
2010-401 Fire Department Module

2020-001 Printer

2030-001 Fire Alarm Adder Supply

**OPTIONS:** Refer to listee's data sheet for the description of optional accessories. When required,

accessories shall be CSFM listed. This listing includes:

2002-002/401, 2006-003/004, 2010-101/102, 2010-104/201/202/X202/401, 2016-002/901, 2030-900, 8558-401/501/B601/B901, 6296B-100, 6297B-100/R100/300, 6298B-R100.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and

ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as a fire alarm control unit for use with separately listed compatible initiating and

indicating devices. If a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal.

Refer to manufacturer's Installation Manual for details.

**NOTE:** 1. Security and other non-fire functions were not examined.

2. Formerly 7170-0073:143 and 7165-1388:141

11-02-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 23, 2004 Listing Expires June 30, 2005

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager